

भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान, पुणे INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH PUNE

(An Autonomous Institution, Ministry of Human Resource Development, Govt. of India)
IISER Pune Campus, Dr. Homi Bhaba Road, Pune-411 008.
Ph. No 020 2590 8001 Fax 020 2588 7499 / 2589 8022

No: 54(2) /IISER/Pune/2019-20/ 06

Dated 08/01/2020

NOTICE INVITING QUOTATION

Sealed quotations are hereby <u>Recall</u> by the undersigned on behalf of the Director, IISER Pune for the work mentioned below up to **3.00 PM on 15/01/2020** from approved and eligible contractors registered with CPWD, Maharashtra State PWD, Railways, MES in appropriate category for electrical/ (B&C) works for the work mentioned below. The quotations will be opened at 3.30 PM on the same day.

Name of work: - Augmentation of work for shopping facility at sport pavilion at IISER Pune (Electrical)

Issue to - Name and address of the agency -

Executive Engineer,

kulkami

IISER Pune

Terms and Conditions:

- 1) The applicant should be registered (ANY ONE) with CPWD in western region, Maharashtra State PWD, MES, Railways in appropriate category for electrical / (B & C) works. The registration certificate should be valid till the last date of receipt of tender. Applicant should submit attested or notarized copies of the valid registration certificate along with quotation.
- 2) Time period for completion of work shall be **07** (Seven) days from the date of placing the work order by IISER Pune. The act of backing-out after quotation will debar such agencies for participating in future quotations of IISER PUNE. Bidder may e-mail queries on maintenance@iiserpune.ac.in or submit to IISER PUNE office in hard copy on all working days before a day of submission date of quotation.
- 3) Quotation can be obtained from IISER PUNE Engineering office at Main Building between 10 AM to 4 PM on all working days before date of submission. Applicant may quote by downloading quotation document from IISER PUNE website.
- 4) All agencies need to submit their quotation in hard copy in a sealed envelope to this office by suitable means on and before **3 PM on 15/01/2020.** Quotation received after the date & time specified above shall not be accepted. Any delays, postal delay etc. will not be entertained. Agency should quote for all the items in the in the BOQ. The bid shall be submitted in the original Bid document (as issued by the IISER, Pune) super scribing the name of work. Rates quoted in the words shall be treated as final for deciding L1 bidder.

Quotations will be opened on the same day (15/01/2020) at 3.30 PM in the presence of agency their authorized representatives, if any. The offer of the agency should be commercially clear

including acceptance of all terms and conditions of this Quotation by the agency. IISER Pune reserves the right to accept or reject the quotation/s without assigning any reasons.

- 6) Quotations submitted with any conditions shall be treated as 'Conditional Quotation' and shall be summarily be rejected by IISER PUNE.
- 7) Quoted rates should be inclusive of cost of all the materials, labour cost, GST, all taxes, octroi, duties, cost of sample and fees towards testing of materials in labs, royalties etc. complete. Nothing extra shall be paid separately.
- 8) All approved makes shall be as per list attached with this and as per CPWD and manufactures specifications. Agency should put-up technical data and obtain prior approval on makes of various materials of IISER PUNE before taking-up work.

The successful agency shall make his own arrangement for all Tools & tackles for work etc complete in view of completion of work. Electricity shall be provided free of cost to agency at one source, agency should make own arrangement to safely tap of power from source to work location.

No advance payment shall be made by IISER Pune.

Quoted rates should be including GST, TDS and other applicable taxes and cess will be deducted from the bills of the work as applicable.

- 9) Specification for the work to be carried out as per BOQ, latest CPWD specification, IS specifications, manufactured specification & as per instruction of IISER PUNE whenever specification CPWD/ IS specification are not available.
- 10) The contractor shall ensure that minimum wages should be paid to the labours and employees in accordance with labour laws.
- 11) L1 Agency to submit actual measurements and abstract sheet to IISER PUNE within 30 days from completion of work.

THE WALL STATE OF THE SERVICE STATE OF THE SERVICE

Executive Engineer,

IISER Pune

Encl: - 1. Schedule of Quantity

2. Approved Make list for electrical

Sign & stamp of Agency-



	APPRO	APPROVED MAKELIST FOR ELECTRICAL
		IISER PUNE
S.No.	Material	Make
н	Instrument Transformers Indicating	Kappa/Kalpa/Voltamp
	Meters	
2	Analog	Meco/Rishab/AE/HPL
т	Digital	Meco/AE/ Socomec/Conzerv/SECURE/HPL
4	Indicating Lamps	GE/SCHNEIDER/ Teknic/L&T/ALTOS, (MULTIPLE LEDs)
ru.	PLC / Digital Load Monitor / Power	Electrex/Allen Bradley/GE/Schneider/Conzerv
	monitor	
9	Panel Accessories / Terminal block	Dirak/Elmax/phoenix/Wago
7	Timers	L& T/Minilec/ Siemens/ GE/ Schneider
∞	TVSS	ASCO /Schneider/ABB
6	Cable Terminating Kits	Raychem Heat Shrinkable/3M/CCI
10	Earthing	Erico/Nimbus/Ashlok
11	MV Switch Boards (LT panels)	Accusonic /Load Controls /Elins / Lotus Switchgear /
8		Pace Switch gears/ Suvarna Electricals
12	Moulded Case Circuit Breaker	GE (Spectra / Record)/Schneider (COMPACT)/ L & T (0 SINE)/ABB/MDS
		Legrand
13	MCB Distribution Board	Legrand/Schneider/Siemens
14	Miniature Circuit Breaker	MK/Legrand /Siemens/Schneider
15	ELCB / RCBO	MK/Legrand /Siemens/Schneider
16	Earth Leakage Relay	MK/Legrand /Siemens/Schneider
17	LT Cables (XLPE)	Polycab/Finolex/CCI



Polycab/Finolex/CCI	Dowells/SMI/CCI/Electrowerke	Precision/DIAMOND/Finolex/Polycab	BEC/BI,	Legrand Mosaic/MK/Schneider/ Anchor(Ave)	Legrand Mosaic/MK/Schneider/ Anchor(Ave)	Philips / Wipro/ GE	Wipro/Asian/Siska /Philips	Crompton greaves (high breeze)/ Bajaj Super Model /Usha	Alstom/Almonard/Usha/CGL	Delton/Finolex/ Polycab	Anchor /MK (Suitable to mount on Legrand DLP trunking) /	Elmex	Legrand Mosaic/Mk/Schneider,	Anchor/Legrand/MK	Storrax/ Skaber/Profab	Storrax/ Skaber/Profab	LEGRAND/ MK/Schneider	LEGRAND/ MK/Schneider	Philips/Wipro/GE	Philips/Wipro/GE	Philips/Wipro/GE	D-Link/Legrand/Polycab	Philips/Wipro /GE/Philips		Legrand Mosaic/ MK/Schneider/Anchor
PVC Insulated copper wire FRLS	Cable Glands	PVC Rigid conduits	M S Conduits	Switches, Sockets, Plug etc	Ceiling rose / HOLDERS	Light fitting, Flourscent CFL/GLs	LED Light fitting	Ceiling Fan	Exhaust Fans	Telephone Cables	Telephone Sockets	Terminal Junction boxes	Power Socket Industrial type	TV Outlet	Cable trays	Metallic raceways	PVC raceways / PVC DLP trucking	Aluminium raceways	Surface / Recess mounted FTL fixtures	Recess mounted down lighter	Wall mounted luminaire	Data Cable - CAT-6	External light fittings/ Garden Light	fittings	Base plates and face plates
18	19	20	21	77	23	24	25	56	27	28	53	30	31	32	33	34	35	36	37	38	39	40	41		42

run loaden paren panels	D link or RR
Data patch cords	D link or RR
Fire Alarm Control Panel	Notifier / Edward / Bosch / Cooper/ Siemens
Repeater Panel	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Smoke Detector	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Multi Sensor Detector	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Heat Detector	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Strobe Cum Sounder	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Sounder / Hooter	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Manual Call point	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Monitor Module	Notifier / Edward / Bosch / Cooper/ Siemens
Addressable Control Module	Notifier / Edward / Bosch / Cooper/ Siemens
FRLS Armoured Cable	Finolex /Polycab /Lapp
Other Items	Approval of Engineer In charge.
Isolation Transformer	Numeric Digital system (Novature)/ Neelkanth power solution/Ador
	powertrans
	patch cords n Control Panel ester Panel e Smoke Detector lulti Sensor Detector lulti Sensor Detector Sounder / Hooter Manual Call point e Control Module moured Cable ner Items Transformer





IISER Pune

(BOQ) Scheduled of quantity

r No.	Description	Qty	Unit	Rates in figure and words	Amount
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1,5 sq.mm FR PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit/Casing Caping with modular switch, modular plate, suitable GI / PVC box and earthing the point with 1.5 sq.mm, FR PVC insulated copper conductor single core cable etc as required.				
1.1	Group C	15.00	Points		
2	Wiring for circuit/ submain wiring along with earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit/Casing Caping as required.				
2.1	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire	60.00	Mtr		
2.2	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	30.00	Mtr		
3	Supplying and fixing suitable size GI/ PVC box with modular plate and cover in front on surface or in recess, including providing and fixing 6 pin 5/6 & 15/16 A modular socket outlet and 15/16 A modular switch, connections etc. as required	5.00	Each		
4	Supplying & installation of wall mounting fan with Pull cord control for speed and oscillation on-off, 1330 RPM, Air delivery- 45 CMM, 45 watts for operation on 230V, Single phase A.C. supply. The fan shall be green as per BEE norms.	4.00	Nos.		
5	Supply and fixing of recess/celling mounted 20 watt LED 4 feet luminaire complete with lamp and all accessories. Including the cost of all materials, labour, HOM of equivalent and machineries all lead lift, loading and unloading, transportation, if any other incidental charges at all level complete all as per specification & as directed by Engineer in charge. Make -Philips, Wipro, Hawells or equivalant.	10.00	Nos.		
	Total				





** 4