

Bid Document

Bid Details	
Bid End Date/Time	16-03-2020 11:00:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Human Resource Development
Department Name	Department Of Higher Education
Organisation Name	Indian Institute Of Science Education And Research (iisers)
Office Name	Pune 411008
Total Quantity	600
Item Category	LED Luminaire (Recessed Luminaire) (PAC Only) , LED Luminaire (Recessed Luminaire) (PAC Only) , LED Luminaire (Recessed Luminaire) (PAC Only) , LED Luminaire (Recessed Luminaire) (PAC Only) , LED Luminaire (Recessed Luminaire) (PAC Only) , LED Luminaire (Recessed Luminaire) (PAC Only)
MSE Exemption For Years Of Experience And Turnover	Yes
Startup Exemption For Years Of Experience And Turnover	Yes
Document required from seller	Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Primary product category	LED Luminaire (Recessed Luminaire)

EMD Detail

Advisory Bank	State Bank of India
EMD Percentage(%)	2.00
EMD Amount	10404

ePBG Detail

Required	No
----------	----

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Director Indian Institute Of Science Education And Research Pune
 Indian Institute of Science Education and Research Pune (IISERs), Dr.Homi Bhabha Road, Pashan
 Pune-411008,
 (Director)

Splitting

Bid splitting not applied.

LED Luminaire (Recessed Luminaire) (100 pieces) (Under PAC)

Make	syska
Model	ssk-pab-6060-b

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS:	Class I	*

	10322 (Part-1)		
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	36W	36W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color temprature (+/- 500 K)	6000 deg K	*
	Type of fixture (in feet)	2x2(30W to 48W)	2x2(30W to 48W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*
	The luminaire body must be corrosion resistant epoxy powder coated / anodizing	Yes	*
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	2	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*

	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)	Yes	*
OPTICAL MANAGEMENT	LED chip Efficacy (≥ 130 Lm/Watt for 6000 deg K, ≥ 120 Lm/Watt for 4000 deg K, ≥ 110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥ 80	*
	Beam Angle	≥ 120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +55 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	> 100 M ohm	*
	The luminaire shall be protected against surges and transients	Yes	*

	of ≥ 2.5 KV		
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA / LUMENMAX	*
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 &TM21(Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the	Yes	*

LED Chip being used in the luminaire)		
Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for recessed type shall comply with Complusory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Suraj Balkrishna Hande	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	100	15

LED Luminaire (Recessed Luminaire) (200 pieces) (Under PAC)

Make	syska
------	-------

Model	ssk-rdl-r-15w
-------	---------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	16W	16W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color temperature (+/- 500 K)	6000 deg K	*
	Type of fixture (in feet)	1x1 (for 3W to 16W)	1x1 (for 3W to 16W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*

	The luminaire body must be corrosion resistant epoxy powder coated / anodizing	Yes	*
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)	Yes	*
OPTICAL MANAGEMENT	LED chip Efficacy (≥130 Lm/Watt for 6000 deg K, >/=120 Lm/Watt for 4000 deg K, >/=110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥80	*
	Beam Angle	≥120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*

	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +55 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of >/=2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA /	*

	LUMENMAX	
LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
LM 80 & TM21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for recess type shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by

Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	200	15

LED Luminaire (Recessed Luminaire) (50 pieces) (Under PAC)

Make	syska
Model	syska18wdownsurfacelight

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS:	Type 3	*

	16103(Part-2)/2012		
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	18W	18W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color tempeature (+/- 500 K)	6000 deg K	*
	Type of fixture (in feet)	1x2 (18W to 28W)	1x2 (18W to 28W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*
	The luminaire body must be corrosion resistant epoxy powder coated / anodizing	Yes	*
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the	Yes	*

	value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)		
OPTICAL MANAGEMENT	LED chip Efficacy (≥ 130 Lm/Watt for 6000 deg K, ≥ 120 Lm/Watt for 4000 deg K, ≥ 110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥ 80	*
	Beam Angle	≥ 120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +50 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall	Engraved/Embssed	*

	available on the body of the Luminaire		
	Each LED luminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA / LUMENMAX	*
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
	Availability of test	Yes	*

Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standard IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012		
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for recessed type shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	50	15

LED Luminaire (Recessed Luminaire) (150 pieces) (Under PAC)

Make	syska
Model	syska12wrdl

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	12W	12W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color temperature (+/- 500 K)	6000 deg K	*
	Type of fixture (in feet)	1x2 (3W to 16W)	1x2 (3W to 16W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Acrylic	*
	The luminaire body must be corrosion resistant epoxy powder	Yes	*

	coated / anodizing		
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)	Yes	*
OPTICAL MANAGEMENT	LED chip Efficacy (≥130 Lm/Watt for 6000 deg K, >=120 Lm/Watt for 4000 deg K, >=110 Lm/Watt for 3000 deg K)	Yes, with higher efficacy >=140 Lm/Watt	Yes, with higher efficacy >=140 Lm/Watt
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥80	*
	Beam Angle	≥120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated for a temperature of	Yes	*

	105 deg. celsius or better		
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +55 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	Other than EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA / LUMENMAX	*

LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
LM 80 &TM21(Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for rcess type shall comply with Complusory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	150	15

LED Luminaire (Recessed Luminaire) (50 pieces) (Under PAC)

Make	syska
Model	syskassk-sds-12w-n

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*

	Rating of Recess type LED Luminaire/System Wattage/Rated Power	12W	12W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color tempeprature (+/- 500 K)	3000 deg K	*
	Type of fixture (in feet)	1x2 (18W to 28W)	1x2 (18W to 28W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*
	The luminaire body must be corrosion resistant epoxy powder coated / anadozing	Yes	*
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥85	*
	Total Harmonics Distortion (≤ 20% (for upto 20W) (</=10% (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the	Yes	*

	manufacturer (as per Cl 8 of IS:16104:2012 lates)		
OPTICAL MANAGEMENT	LED chip Efficacy (≥ 130 Lm/Watt for 6000 deg K, ≥ 120 Lm/Watt for 4000 deg K, ≥ 110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥ 80	*
	Beam Angle	≥ 120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +55 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body	Engraved/Embssed	*

	of the Luminaire		
	Each LED luminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA / LUMENMAX	*
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
	Availability of test Report from Central	Yes	*

Government Lab /NABL/ILAC accredited lab to Indian Standard IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012		
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for recessed type shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008,Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	50	15

LED Luminaire (Recessed Luminaire) (50 pieces) (Under PAC)

Make	syska
Model	syskasurface15wsquareround(ssk-sdcscs)172x172x40h172x40h

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	16W	16W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color temperature (+/- 500 K)	3000 deg K	*
	Type of fixture (in feet)	1x1 (for 3W to 16W)	1x1 (for 3W to 16W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*
	The luminaire body must be corrosion	Yes	*

	resistant epoxy powder coated / anodizing		
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	2 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥ 85	*
	Total Harmonics Distortion ($\leq 20\%$ (for upto 20W) ($\leq 10\%$ (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)	Yes	*
OPTICAL MANAGEMENT	LED chip Efficacy (≥ 130 Lm/Watt for 6000 deg K, ≥ 120 Lm/Watt for 4000 deg K, ≥ 110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥ 80	*
	Beam Angle	≥ 120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*
	Capacitor shall be rated	Yes	*

	for a temperature of 105 deg. celsius or better		
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +50 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA / LUMENMAX	*

LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
LM 80 &TM21(Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for rcess type shall comply with Complusory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	John Albert K	411008, Indian Institute of Science Education and Research, Pune (IISER) Dr.Homi Bhabha Road , Pashan Pune 411008 Email: purchase@iiserpune.ac.in For Payment Status: 020 2590 8180/8452 For Delivery Status : 020 2590 8246, PUNE CITY, 411008	50	15

Bid Specific Additional Terms and Conditions

1. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
2. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
3. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.
4. OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.
5. Scope of supply (Bid price to include all cost components) : Only supply of Goods
6. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 7 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---